

**SEWERAGE SERVICES DEPARTMENT SARAWAK
JABATAN PERKHIDMATAN PEMBETUNGAN SARAWAK**

Desludging Volume for Miri Sludge Treatment Plant

Seventh Year of Operation (Targeted Volume for MCC: 25,000 m³)

	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
MCC	3,286	1,964.1	2,980.5	2,718.8	2,347.7	1,600.4	2,474.7	2,285.6	1,791.8	1,416.5	967.1	1,373.2
Other	-	-	-	-	-	-	-	-	-	-	-	-
Total	3,286	1,964.1	2,980.5	2,718.8	2,347.7	1,600.4	2,474.7	2,285.6	1,791.8	1,416.5	969.5	1,373.2

Properties Desludged (nos.)

	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
MCC	1,276	628	1,377	836	800	566	737	624	613	397	243	251
Other	-	-	-	-	-	-	-	-	-	-	1	-
Total	1,276	628	1,377	836	800	566	737	624	613	397	244	251

Effluent Standard Monitoring (mg/L)

Parameter	Standard A	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
BOD₅	20	9	9	15	21	17	16	10	14	10	20	8	8
COD	120	47	45	73	101	81	79	48	70	50	98	39	40
SS	50	9	6	51	46	30	10	13	16	14	9	8	34