

Sewerage Services Department Sarawak
Jabatan Perkhidmatan Pembetungan Sarawak

Year 2023 Tahun 2023	Effluent Result (mg/L) Keputusan Efluen (mg/L)							
Date	BOD ₅	COD	SS	O & G	Ammoniacal Nitrogen	Nitrate Nitrogen	Temperature °C	pH Value
27.1.2023	10	43	30	N.D	0.20	2.40	28.60	6.96
19.01.2023	11	47	9	N.D	0.20	2.10	29.30	7.17
11.01.2023	9	42	14	N.D	0.17	2.80	28.90	7.10
05.01.2023	7	30	13	N.D	0.14	3.00	27.40	7.27
22.02.2023	5	22	10	N.D	0.19	4.10	29.60	7.05
15.02.2023	5	23	13	N.D	0.20	4.40	29.20	7.17
08.02.2023	13	57	12	N.D	0.14	3.90	29.30	7.21
01.02.2023	6	25	12	N.D	0.14	1.10	28.50	7.07
22.03.2023	5	23	14	N.D	0.22	4.80	29.40	7.31
15.03.2023	6	28	17	N.D	0.18	4.90	28.40	7.31
08.03.2023	6	26	14	N.D	0.33	4.20	28.50	7.03
01.03.2023	6	27	24	N.D	0.21	4.80	27.20	7.04
27.04.2023	8	33	12	N.D	0.26	1.80	29.70	7.48
19.04.2024	6	27	16	N.D	0.14	2.50	31.10	7.22
12.04.2025	11	48	16	N.D	0.29	2.60	30.40	7.26
05.04.2026	7	30	24	N.D	0.19	3.40	29.90	7.03
24.05.2023	4	17	9	N.D	0.25	4.20	30.10	6.96
17.05.2023	7	30	20	N.D	0.30	1.50	31.30	7.15
10.05.2023	8	35	12	N.D	0.24	1.30	29.70	7.20
05.05.2023	8	35	11	N.D	0.15	2.30	31.20	7.33
08.06.2023	7	29	14	N.D	0.22	3.70	30.50	7.10
14.06.2023	10	42	18	N.D	0.52	1.50	31.20	7.22
21.06.2023	6	29	17	N.D	0.15	4.40	29.80	7.16
28.06.2023	6	29	17	N.D	0.15	4.80	31.00	6.84
05.06.2023	7	30	7	N.D	0.19	3.10	30.20	7.14
12.07.2023	9	40	10	N.D	0.21	4.00	30.20	7.17
20.07.2023	6	28	7	N.D	0.21	3.20	31.40	7.48
26.07.2023	4	20	4	N.D	0.19	4.20	30.90	7.65
02.08.2023	4	19	7	N.D	0.10	1.70	30.90	7.71
09.08.2023	5	23	15	N.D	0.33	4.40	30.20	6.89
16.08.2023	8	35	10	N.D	0.36	2.20	30.70	7.09
23.08.2023	4	17	19	N.D	0.18	3.70	28.70	7.13
06.09.2023	8	34	21	N.D	0.21	3.10	30.40	7.19
13.09.2023	6	26	17	N.D	0.32	2.00	29.80	7.16
20.09.2023	8	37	27	N.D	0.28	1.70	29.80	7.17
27.09.2023	6	27	22	N.D	0.71	5.40	30.30	7.01
04.10.2023	9	43	12	N.D	0.98	2.50	30.60	7.18
11.10.2023	8	36	18	N.D	6.10	3.30	30.90	6.99
18.10.2023	10	45	15	N.D	2.08	3.90	31.00	6.93
25.10.2023	6	25	14	N.D	3.00	4.70	24.60	7.01
01.11.2023	6	26	13	N.D	4.25	8.60	30.20	7.10
08.11.2023	4	18	11	N.D	6.90	9.00	29.80	7.11
15.11.2023	12	52	17	N.D	4.72	5.50	30.10	6.94
22.11.2023	6	29	16	N.D	3.00	6.30	30.50	6.52
06.12.2023	14	59	9	N.D	0.69	3.10	29.90	7.10
13.12.2023	5	22	12	N.D	0.23	3.60	29.60	7.00
20.12.2023	12	53	28	N.D	0.55	3.00	28.90	7.27
28.12.2023	6	26	14	N.D	0.14	7.10	30.70	7.60

Note:

Data is supplied by operator (Sar-Alam Indah Sdn Bhd).