

**SEWERAGE SERVICES DEPARTMENT SARAWAK  
JABATAN PERKHIDMATAN PEMBETUNGAN SARAWAK**

**Desludging Volume for Sibu Sludge Treatment Plant**

**2011 (Target Volume for SMC : 10,000 m<sup>3</sup>)**

	Mac	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
<b>SMC</b>	1150	1169	1144	1076	947	983	1207	1066	823	437
<b>Other</b>	-	-	8	5	2	2	13	14	4	116
<b>Total</b>	1150	1169	1152	1081	949	985	1220	1080	827	553

**Property Desludged (nos.)**

	Mac	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
<b>SMC</b>	76	59	63	208	385	402	437	349	167	67
<b>Other</b>	-	-	2	2	1	1	4	3	2	9
<b>Total</b>	76	59	65	210	386	403	441	352	169	76

**Effluent Standard Monitoring (mg/l)**

Parameter	Standard A	Mac	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
<b>BOD<sub>5</sub></b>	20	5.45	10.50	6.00	7.00	8.00	8.00	11.00	8.00	11.00	8.00
<b>COD</b>	120	-	47.50	21.00	23.00	19.00	38.00	40.00	39.00	41.00	41.00
<b>SS</b>	50	9.77	18.50	5.00	4.00	3.00	4.00	6.00	5.00	12.00	9.00