

SEWERAGE SERVICES DEPARTMENT SARAWAK
JABATAN PERKHIDMATAN PEMBETUNGAN SARAWAK

Desludging Volume for Sibu Sludge Treatment Plant

2012 (Target Volume for SMC: 10,000 m³)

	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
SMC	675	919	1168	1128	1252	1581	1926	1317	1240	1395	1659	843	15103
Other	18	4	15	4	18	119	9	13	6	73	0	12	291
Total	639	923	1183	1132	1270	1700	1935	1330	1246	1468	1659	855	15394

Property Desludged (nos.)

	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
SMC	246	370	510	509	554	644	709	536	571	643	791	374	6457
Other	4	2	7	2	4	4	3	5	2	3	0	4	40
Total	250	372	517	511	558	648	712	541	573	646	791	378	6497

Effluent Standard Monitoring (mg/l)

Parameter	Standard A	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
BOD₅	20	9	5	5	9	12	12	8	8	6	18	7	5
COD	120	36	25	23	38	48	49	33	35	24	29	29	22
SS	50	5	9	4	7	4	10	11	9	15	4	11	10