

**SEWERAGE SERVICES DEPARTMENT SARAWAK
JABATAN PERKHIDMATAN PEMBETUNGAN SARAWAK**

Desludging Volume for Sibu Sludge Treatment Plant

2016 (Targeted Volume for SMC : 25,000m³)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
SMC	2504.6	1803.6	2395.8	1842.1	2009.8	2172.1	2326.1	2,933.6	2660.4	2,499.7	1,852.2	-
Other	2.70	33.5	6.0	15.4	16.0	2.6	4.60	-	-	29.5	65	-
Total	2507.3	1837.1	2401.8	1857.5	2025.8	2174.7	2,330.7	2,933.6	2660.4	2529.2	1,917.2	-

Properties Desludged (nos.)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
SMC	688	755	929	704	822	774	895	1072	1048	886	468	-
Other	1	2	1	1	1	1	2	-	-	4	1	-
Total	689	757	930	705	823	775	897	1072	1048	890	469	-

Effluent Standard Monitoring (mg/L)

Parameter	Standard A	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
BOD₅	20	12	5	8	6	13	8	15	9	15	15	12	-
COD	120	58	23	37	29	63	37	75	47	76	76	56	-
SS	50	8	1	10	18	11	4	29	39	40	37	38	-