

**EFFLUENT AND DRYNESS OF DRY SLUDGE
RESULT FOR 2026**

Sampling Date	Temp. °C	pH Value	BOD ₅	COD	SS	Oil & Grease	Ammoniacal Nitrogen	Nitrate Nitrogen	Phosphorus	Dry Sludge Dryness
Standard A	≤40 °C	6-9	≤20	≤120	≤50	≤5	≤10	≤20	≤5	≥20%
January										
08/01/2026	28.0	6.8	<2.0	19.4	15	ND(<1.0)	0.32	0.25	0.80	22
15/01/2026	28.0	6.9	<2.0	15.5	1	ND(<1.0)	0.12	0.51	0.76	21
22/01/2026	29.0	6.9	2.2	34.8	1	ND(<1.0)	0.09	0.04	0.91	24
29/01/2026	28.0	6.9	<2.0	15.2	1	ND(<1.0)	0.14	0.51	0.60	22
February										
05/02/2026	28.0	6.5	2.0	32.8	37	ND(<1.0)	0.14	0.08	0.51	NA
12/02/2026	28.0	7.5	2.5	31.0	1	ND(<1.0)	0.17	0.57	0.44	NA
19/02/2026	27.0	6.9	<2.0	23.6	1	ND(<1.0)	0.25	0.05	ND(<0.02)	NA
26/02/2026	27.0	6.8	<2.0	28.1	1	ND(<1.0)	0.20	0.13	0.52	NA
March										
05/03/2026	27.7	6.9	4.4	22.5	18	ND(<0.5)	ND<0.1	0.19	0.94	NA
12/03/2026	27.1	7.1	1.3	27.0	12	ND(<0.5)	ND<0.1	5.37	0.87	NA
19/03/2026	28.2	7.2	1.3	27.3	11	ND(<0.5)	ND<0.1	5.9	0.67	19
26/03/2026	33.2	7.3	1.4	9.1	10	ND(<0.5)	ND<0.1	11.65	1.07	20
April										
02/04/2026	30.3	7.4	1.4	9.9	8.5	ND(<0.5)	ND<0.1	12.3	2.9	21.2
09/04/2026	28.1	7.1	1.8	15.8	12.0	ND(<0.5)	ND<0.1	5.8	0.9	21.1
16/04/2026	29.0	7.3	2.0	15.9	17.0	ND(<0.5)	ND<0.1	4.4	0.8	22.2
23/04/2026	30.1	7.2	<2.0	11.1	16.0	ND(<0.5)	ND<0.1	9.5	0.8	22.6
30/04/2026	28.5	7.2	1.4	4.4	9.5	ND(<0.5)	ND<0.1	7.7	1.3	22.3
May										
07/05/2026	28.7	7.1	1.5	4.6	16	ND(<0.5)	ND<0.1	7.45	1.24	21.6
14/05/2026	29.0	7.4	<2.0	7.6	8	ND(<0.5)	ND<0.1	6.89	0.20	23.8
19/05/2026	28.1	7.2	<2	17.1	5	ND(<0.5)	ND<0.1	6.73	0.28	24.2
25/05/2026	29.3	7.1	<2	18.6	11	ND(<0.5)	ND<0.1	8.19	1.42	28.9
June										
05/06/2026	29.7	7.2	<2	16.3	15	ND(<0.5)	ND<0.1	8.52	1.19	25.6
11/06/2026	29.1	7.1	3.5	19.6	22	ND(<0.5)	ND<0.1	7.47	1.57	25.6
18/06/2026	28.5	7.6	<2	21.4	3	ND(<0.5)	ND<0.1	5.01	0.63	22.8
25/06/2026	27.6	7.4	<2	7.9	3	ND(<0.5)	ND<0.1	7.59	0.45	23.5
July										
02/07/2026	25.9	7.3	<2.0	15.7	11	ND(<0.5)	ND<0.1	6.78	0.98	25.2
06/07/2026	29.4	7.4	1.5	20.4	5	ND(<0.5)	ND<0.1	7.22	1.2	28.1
17/07/2026	29.1	7.2	<2.0	ND<4.0	9	ND(<0.5)	ND<0.1	4.48	1.17	27.7
23/07/2026	26.5	6.7	<2.0	8.4	7	ND(<0.5)	ND<0.1	7.98	1.4	25.2
29/07/2026	28.0	7.3	<2.0	15.0	7	ND(<0.5)	5	1.92	0.8	NA
August										
06/08/2026	28.9	7.5	1.6	14.8	7	ND(<0.5)	2.30	5.55	0.91	25.7
13/08/2026	25.7	7.5	<2.0	19.6	3	ND(<0.5)	ND<0.1	5.28	0.6	22.0
20/08/2026	30.3	7.2	<2.0	15.3	8	ND(<0.5)	ND<0.1	7.58	0.51	26.0
27/08/2026	28.6	7.4	<2.0	13.6	4	ND(<0.5)	ND<0.1	9.30	0.20	25.2

As updated on 01.09.2026