

EFFLUENT AND DRYNESS OF DRY SLUDGE
RESULT FOR 2026

Sampling Date	Temp. °C	pH Value	BOD ₅	COD	SS	Ammoniacal Nitrogen	Nitrate Nitrogen	Phosphorus	Oil & Grease	Dry Sludge Dryness
Standard A	≤40 °C	6-9	≤20	≤120	≤50	≤10	≤20	≤5	≤5	≥20%
January										
08/01/2026	28.0	6.8	<2.0	19.4	15	0.32	0.25	0.80	ND(<1.0)	22
15/01/2026	28.0	6.9	<2.0	15.5	1	0.12	0.51	0.76	ND(<1.0)	21
22/01/2026	29.0	6.9	2.2	34.8	1	0.09	0.04	0.91	ND(<1.0)	24
29/01/2026	28.0	6.9	<2.0	15.2	1	0.14	0.51	0.60	ND(<1.0)	22

As updated on 01.02.2026