

EFFLUENT AND DRYNESS OF DRY SLUDGE
RESULT FOR 2026

Sampling Date	Temp. °C	pH Value	BOD ₅	COD	SS	Ammoniacal Nitrogen	Nitrate Nitrogen	Phosporus	Oil & Grease	Dry Sludge Dryness
Standard A	≤40 °C	6-9	≤20	≤120	≤50	≤10	≤20	≤5	≤5	≥20%
January										
08/01/2026	28.0	6.8	<2.0	19.4	15	0.32	0.25	0.80	ND(<1.0)	22
15/01/2026	28.0	6.9	<2.0	15.5	1	0.12	0.51	0.76	ND(<1.0)	21
22/01/2026	29.0	6.9	2.2	34.8	1	0.09	0.04	0.91	ND(<1.0)	24
29/01/2026	28.0	6.9	<2.0	15.2	1	0.14	0.51	0.60	ND(<1.0)	22
February										
05/02/2026	28.0	6.5	2.0	32.8	37	0.14	0.08	0.51	ND(<1.0)	NA
12/02/2026	28.0	7.5	2.5	31.0	1	0.17	0.57	0.44	ND(<1.0)	NA
19/02/2026	27.0	6.9	<2.0	23.6	1	0.25	0.05	ND(<0.02)	ND(<1.0)	NA
26/02/2026	27.0	6.8	<2.0	28.1	1	0.20	0.13	0.52	ND(<1.0)	NA

As updated on 01.03.2026