

**SEWERAGE SERVICES DEPARTMENT SARAWAK  
JABATAN PERKHIDMATAN PEMBETUNGAN SARAWAK**

**Desludging Volume for Miri Sludge Treatment Plant**

**Sixth Year of Operation (Targeted Volume for MCC: 25,000 m<sup>3</sup>)**

	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
<b>MCC</b>	1,568	1,247	1,728	1,888	1,458	2,260	2,435	3,995	2,525	3,191	3,463	1,411
<b>Other</b>	-	-	-	-	-	-	-	-	-	-	-	-
<b>Total</b>	1,568	1,247	1,728	1,888	1,458	2,260	2,435	3,995	2,525	3,191	3,463	1,411

**Properties Desludged (nos.)**

	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
<b>MCC</b>	613	287	122	652	801	1,139	1,444	1,407	1,148	873	807	410
<b>Other</b>	-	-	-	-	-	-	-	-	-	-	-	-
<b>Total</b>	613	287	122	652	801	1,139	1,444	1,407	1,148	873	807	410

**Effluent Standard Monitoring (mg/L)**

Parameter	Standard A	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
<b>BOD<sub>5</sub></b>	20	12	9	16	8	7	7	11	11	15	15	6.84	10
<b>COD</b>	120	59	46	77	39	36	37	54	53	73	73	12	49
<b>SS</b>	50	5	12	13	12	14	9	38	12	19	19	36	6