

**SEWERAGE SERVICES DEPARTMENT SARAWAK**  
**JABATAN PERKHIDMATAN PEMBETUNGAN SARAWAK**  
(Effluent Quality Monitoring Data / Pemantauan Data Kualiti Efluen)

**1. Dewan Bandaraya Kuching Utara (DBKU)**

Date	Effluent (mg/l)		
	BOD <sub>5</sub> (20 mg/l)	COD (120 mg/l)	SS (50 mg/l)
<b>a) Ong Guan Poh STP</b>			
2009	8.9	43.9	20
2011	<2	14.3	8
2012	8	-	<5
2013	13	-	15
<b>b) Bahai Centre STP</b>			
2009	9	50	23
2011	13.2	34.8	17
2012	48	-	32
2013	50	-	15
2014	37	-	29
<b>c) Central Barat STP</b>			
2009	9	14.6	28
2011	6.6	30.4	59
2012	23	-	31
2013	4	-	5
2014	17	-	30
<b>d) Wisma Bapa Malaysia STP</b>			
2009	2.9	49.8	15
2011	<2	<5.4	9
2012	16	-	37
2013	8	-	24
2014	2	-	2
<b>e) Bukit Siol STP (Headquaters DBKU)</b>			
2009	5.9	32.2	19
2011	6.1	30.4	6
2012	7.7	-	12
2013	5	-	36
2014	2	-	5
2016	33	65	11

**SEWERAGE SERVICES DEPARTMENT SARAWAK**  
**JABATAN PERKHIDMATAN PEMBETUNGAN SARAWAK**  
(Effluent Quality Monitoring Data / Pemantauan Data Kualiti Efluen)

<b>f) Hong Kong Park STP</b>			
2009	9	61.5	25
2011	9.1	26.1	13
2012	58	-	48
2013	30	-	86
2014	2	-	6
<b>g) Cloud Estate STP</b>			
2009	20	79.1	37
2011	9.1	23.9	33
2012	16	-	21
2013	32	-	20
2014	17	-	63
<b>h) Sun Valley STP</b>			
2009	5.9	46.8	14
2011	15.2	35.9	33
2012	20	-	26
2013	5	-	24
2014	6	-	17

**Note:**

This information is supplied by relevant Local Authority and Department of Environment Sarawak

**2. Majlis Bandaraya Kuching Selatan (MBKS)**

Date	Effluent (mg/l)		
	BOD <sub>5</sub> (20 mg/l)	COD (120 mg/l)	SS (50 mg/l)
<b>a) Lintang Park STP</b>			
2012	46	240	38
<b>b) Rockview Estate STP</b>			
2012	35	230	32
2017	30	100	38
<b>c) Poh Ming Park STP</b>			
2006	18	1.6	21

**SEWERAGE SERVICES DEPARTMENT SARAWAK**  
**JABATAN PERKHIDMATAN PEMBETUNGAN SARAWAK**  
(Effluent Quality Monitoring Data / Pemantauan Data Kualiti Efluen)

<b>d) Kenyalang Park STP</b>			
2010	36	100	5
2015	75	280	88
<b>e) KTS Building STP</b>			
2012	37	200	42
2016	27	122	26
<b>f) Kok Yong STP</b>			
2012	66	190	100
<b>g) Pending Height Phase I STP</b>			
2012	110	280	56
2016	80	201	42
<b>h) Pending Height Phase II STP</b>			
2008	302	-	-
<b>i) Lucky Drive STP</b>			
2008	76.7	-	-
2012	15	140	30
<b>j) Thian Guan Garden STP</b>			
2012	66	190	100
2014	39	136	146

**Note:**

- There is no data available for following STP:  
Pecky Park, Sunny Estate, Sri Aman Estate, Wangli Garden, Kenyalang Market and Stutong Central Market
- This information is supplied by relevant Local Authority and Department of Environment Sarawak

**3. Bintulu Development Authority (BDA)**

Date	Effluent (mg/l)		
	BOD <sub>5</sub> (20 mg/l)	COD (120 mg/l)	SS (50 mg/l)
<b>a) Park City Centralised Oxidation Pond</b>			
2010	36	87	9
2011	32	48	8
2012	27	37	4

**SEWERAGE SERVICES DEPARTMENT SARAWAK**  
**JABATAN PERKHIDMATAN PEMBETUNGAN SARAWAK**  
(Effluent Quality Monitoring Data / Pemantauan Data Kualiti Efluen)

<b>b) North-South Road Oxidation Pond</b>			
2010	9	65	17
2011	34	202	153
2012	5	28	6
<b>c) Kidurong Treatment Plant K3 Oxidation Pond</b>			
2010	10	-	17
2011	60	81	<5
2012	7	146	51
<b>d) Sg. Plan Oxidation Pond</b>			
2010	43	-	11
2011	5	77	25
2012	17	69	18

**Note:**

This information is supplied by relevant Local Authority and Department of Environment Sarawak

**4. Majlis Perbandaran Padawan (MPP)**

Date	Effluent (mg/l)		
	BOD <sub>5</sub> (20 mg/l)	COD (120 mg/l)	SS (50 mg/l)
<b>a) Taman Perwira Landeh STP</b>			
2011	25.5	94.9	16
2012	<2	40.5	27
2015	2.4	80.7	7
<b>b) Taman Cahaya Indah Landeh STP</b>			
2016	6.6	75	12
2017	9.5	53.4	31

**Note:**

1. For Taman Boulder Built STP data please refer Plants Operation webpage ([Taman Boulder Built](#))
2. This information is supplied by relevant Local Authority and Department of Environment Sarawak