

**SEWERAGE SERVICES DEPARTMENT SARAWAK
JABATAN PERKHIDMATAN PEMBETUNGAN SARAWAK**

Desludging Volume for Miri Sludge Treatment Plant

Third Year of Operation (Targeted Volume for MCC: 20,000 m³)

	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
MCC	1314	1005	1593	1769	989	1549	1533	3021	3084	3327	945	234
Other	-	-	-	-	-	-	-	-	-	-	-	29
Total	1314	1005	1593	1769	989	1549	1533	3021	3084	3327	945	263

Properties Desludged (nos.)

	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
MCC	337	169	199	281	252	350	205	627	458	502	215	57
Other	-	-	-	-	-	-	-	-	-	-	-	1
Total	337	169	199	281	252	350	205	627	458	502	215	58

Effluent Standard Monitoring (mg/L)

Parameter	Standard A	Jan	Feb	Mac	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
BOD₅	20	12	14	13	12	10	7	6	22	15	11	7	8
COD	120	59	66	61	59	49	34	29	109	74	53	34	39
SS	50	6	3	9	7	6	2	6	8	22	7	11	7